

# Evidence of Performance

Air permeability, Watertightness, Resistance to wind load



## Test Report

No. 12-001914-PR01

(PB-A01-02-en-01)

**Client** SAVOX d.o.o.  
Johovac bb  
75466 Milici  
Bosnia-Herzegovina

**Product** Tilt and turn window

**Designation** System designation: IV 78mm Wood system

**Performance-relevant product details** Material: Wood

**Overall dimensions (WxH)** 1230 mm x 1480 mm

**Special features**

### Basis

EN 14351-1:2006+A1:2010

### Test standard/s:

EN 1026:2000-06  
EN 1027:2000-06  
EN 12046-1:2003-11  
EN 12211:2000-06  
EN 14609:2004-06

Correspond/s to the national standard/s (e.g. DIN EN)

### Representation



### Results

Air permeability according to EN 12207:1999-11



**Class 4**

Watertightness according to EN 12208:1999-11



**Class E900**

Resistance to wind load according to EN 12210:1999-11/AC:2002-08



**Class C4 / B4**

### Instructions for use

The results obtained can be used by the manufacturer as the basis for the manufacturer ITT test report summary. Observe the specifications set out by the applicable product standard.

### Validity

The data and results refer solely to the tested and described specimen. Classification remains valid as long as the product and the above basis remain unchanged. The results can be extrapolated under the manufacturer's own liability subject to observance of the relevant specifications set out by the applicable product standard. This test/evaluation does not allow any statement to be made on any further characteristics regarding performance and quality of the construction presented, in particular the effects of weathering and ageing were not taken into account.

### Notes on publication

The ift-Guidance Sheet "Advertising with ift test documents" applies. The cover sheet can be used as an abstract.

The report contains a total of 20 pages.

ift Rosenheim

13.07.2012

Jörn Peter Lass, Dipl.-Ing. (FH)  
Head of Testing Department  
Building Components

Robert Kolacny, Dipl.-Ing. (FH)  
Deputy Head of Testing Department  
Building Components